

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

No. 1155Date: 2/4/24

It is certified that an inspection team headed by Executive Engineer  
E. R. Abhishek Rastogi (Name of Officers  
with designation) from PH Division Gaya. (Name of  
Department/Office) inspected the Secondary Delhi Public  
School Shahid Bhagat Singh Colony, Mustafabad, Gaya. (Name & Address of  
the School) on 28-3-24 and found that the Secondary Delhi Public  
School Shahid Bhagat Singh Colony, Mustafabad, Gaya. (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T. Govt.

The above valid for a period of one yearSignature with Seal : [Signature]

Name

कार्यपालक अभियंता  
लोक स्वास्थ्य प्रमण्डल, गया

Designation

2/4/24

To

Secondary Delhi Public  
School Shahid Bhagat  
Colony, Mustafabad, Gaya.

(Name &amp; Address of the Institution)

Govt. Of Bihar  
**DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)**  
 Public Health Engineering Department  
 P.H. DIVISION, GAYA

Physico-Chemical Bacteriological Examination Report of Drinking Water Sample of Gaya														
Sample Collected By : SDPS Staff		Sample Received on : 23.03.2024												
Sample ID.	Location Details	Turb.	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Bacteria (+,-)	Remarks	
GAYA/W/23-24/2757	Secondary Delhi Public School	0.82	110	71	48	12.83	3.89	12	52	0.18	7.06	Absent		
Reporting Date :	28.03.2024	Desirable Limit	1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	Absent	
Permissible Limit in absence of alternate source IS:10500:2012			5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	Absent	

\*NR-No Relaxation.

  
28/03/2024

Chemist  
P.H. Division, Gaya

जल नमूना का संग्रह दिनांक..... 23/03/24  
 SDPS Staff.....के द्वारा किया गया है।